

Overtime Report September 16th - October 10th, 2022

| Operator | Date | Time | OT Hrs. | Alarm Call | Operator Response |
|-------------|-----------|------------------|---------|------------------------|--|
| John Gibson | 10/4/2022 | 19:59 & 23:01 | 2 | SAF Froth Pump Fail | Acknowledged alarm, logged in remotley/reset/restarted the SAF system. |
| John Gibson | 10/5/2022 | 5:41 | 1 | SAF Froth Pump Fail | Acknowledged alarm, logged in remotley/reset/restarted the SAF system. |