

Overtime Report December, 2023

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
Sean Bernard	12/28/2023	11:39	2	FF Common High Alarm	Responded to the plant, FF's in alarm due to an influent flow control valve fault. Reset and restarted the fuzzy filters.
Sean Bernard	12/29/2023	10:30	2		Daily rounds, reads, labs. Covering for operator on leave.
Sean Bernard	12/30/2023	21:00	2		Daily rounds, reads, labs. Covering for operator on leave.
Sean Bernard	12/31/2023	2:06am & 4 16:00	4	SAF Polymer mixer fail to start alarm.	2:06am Responded to the plant for a SAF poly mixer alarm, cleared and reset the polymer system, brought plant processes back online. 16:00 Daily rounds, reads, labs, shutdown plant processes.