

## Overtime Report October 11th - November 14th, 2022

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
John Gibson	10/26/2022	2:49	1	FF Common High Alarm.	Logged in remotely. FFA in an extended purge cycle due to high turbidity. Purge tank to low to complete the wash cycle. Shut down plant processes.
John Gibson Sean Bernard	11/10/2022	8:50	6.67	Sewer Backup	Call from Graton answering service of a sewer backup at the corner of Graton Rd. and Cecile St. Operators responded to the site and found sewage seeping from around manhole 7-2 (MH 7-2). Coned off area and pumped the sewer from MH 7-2 to the downstream MH 7-3. Contacted MSI who responded and jetted the sewer main. Cleaned up and disinfected the area. The minor backup was completely contained and no sewage entered the creek or storm drains. Notified water quality control board.
Sean Bernard	11/13/2022	16:00	2	FF Common High, SAF pump A&B power fail, SAF system common power fail.	Multiple power fail alarms caused by a power outage. Responded to the plant, acknowledged/reset alarms and system processes.