

Overtime Report June 7th - September 14th 2022

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
Sean Bernard	8/18/2022	20:00	2	SAF Froth Pump Fail	Acknowledged alarm, responded to the plant and reset/restarted the SAF system.
Sean Bernard	8/30/2022	21:30	2	Surge Tank High Level Alarm	Acknowledged alarm and responded to the plant. Opened the surge tank valve and drained below the high level alarm setting.
Sean Bernard	9/14/2022	22:10	1	SAF Froth Pump Fail	Earthquake caused the SAF pump to trip. Acknowledged alarm, logged in and restarted the system.