GRATON COMMUNITY SERVICES DISTRICT
250 ROSS LANE • MAIL: PO BOX 534, GRATON, CALIFORNIA 95444 • 707/823-1542

**DATE:** October 21st, 2026
**TO:** Members of the Board of Directors
**FROM:** John Gibson, Chief Plant Operator

**SUBJECT: SEPTEMBER, 2026 OPERATION REPORT**

**Regulatory Compliance**

- **CIWQS:** Submitted the **"No Spill"** certification for the month of **SEPTEMBER**.
- **Sewer Lateral Certificate of Compliance**: 8290 Green Valley Rd.

**Sampling and Monitoring**

- **GCSD** irrigated **2.097** million gallons of recycled water on site.
- **Kendal Jackson Vineyards** recycled water use for the month of July: **.474 MG.**

**Operations Report: Operations, Process Control, and Preventative Maintenance**
The following activities were carried out as part of our ongoing efforts to ensure efficient operations, maintain process control, and implement preventative maintenance measures:

- Repaired a leaking irrigation meter flange, replaced failed gasket.
- Repaired the damaged power cable for the 3 HP discharge pump. (rat chewed on the cable) Pulled pump, tested and placed back in service.
- Replaced a damaged recycled water turnout valve that was damaged by Sonoma County Parks during mowing operations along the Joe Rodota Trail.
- Cleaned and washed the Fuzzy Filters using a bleach solution, drained the filters, and measured media depth. Added media to both filters to restore the depth to manufacturer specifications. Performed a comprehensive deep cleaning of the Fuzzy Filter system, including the filter media, meters, influent lines, effluent lines, and drain lines. Replaced Fuzzy Filter B turbidity meter bulb and calibrated all turbidity meters.
- A power surge caused the CCB chlorine analyzer to malfunction. Telstar was dispatched to diagnose the issue and complete the necessary repairs.
- MSI completed the annual cleaning of Lift Station No. 1 and performed CCTV inspection of the sewer main section at the intersection of Oak Grove Avenue and Donald Street.

**There was no overtime in September 2026.**