

Overtime Report July 15th - August 11th 2022

| Operator | Date | Time | OT Hrs. | Alarm Call | Operator Response |
|-------------|----------|------|---------|---------------------|--|
| John Gibson | 8/3/2022 | 3:34 | 1 | SAF Froth Pump Fail | Acknowledged alarm, Logged in to SCADA and reset/restarted the SAF froth pump. |